

Technical Information

Test periods

Function testing of a residual current circuit-breaker should be carried out at regular intervals. Which testing intervals are appropriate and/or prescribed depends on the type of installation, the ambient conditions and the applicable installation regulations for the electrical system. That is why the manufacturer cannot specify a universally applicable test cycle.

Furthermore, the guidelines and information of other institutions and associations – e.g. of professional associations or VdS – should be taken into account.

We recommend regularly testing the residual current circuit-breaker by pressing the test button. In the case of intended use, this should be done at least once per year. The residual current circuit-breaker must trip during this process.